

CERTIFICATE OF COMPLIANCE

Certificate Number 20160219-MH61332
Report Reference MH61332-19921116
Issue Date 2016-FEBRUARY-19

Issued to: DELTA DUCT AIRCONDDITIONING
Plot No.533-137,Factory:2
PO Box: 5389, Dubai Industrial City, Saih Shuaib 4
UNITED ARAB EMIRATES

**This is to certify that
representative samples of**

AIR DUCTS
Class 1 flexible; sizes 3 through 20 in. (102 mm - 508 mm)
designated as "Delta-Flex."

The duct consists of a wire helix reinforced film core, wrapped with a fiberglass insulation which in turn is covered with a vapor barrier material. Depending on the insulation used, a reinforced vapor barrier or reinforcing scrim may be required. See under Fiberglass Insulation to determine whether reinforcement is necessary.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 181, Factory-Made Air Ducts and Air Connectors .
ULC-S110, Standard Methods of Test for Air Ducts .

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

